Interior Drainage Analysis Tributary of Smith Canal Stockton, CA

April 2010

Prepared By:

Kjeldsen, Sinnock & Neudeck, Inc. 711 N. Pershing Avenue Stockton, CA 95203 209-946-0268

Prepared For:

San Joaquin Area Flood Control Agency

ENGINEER'S SIGNATURE PAGE

This interior drainage analysis prepared for San Joaquin Area Flood Control Agency:

INTERIOR DRIANAGE ANALYSIS TRIBUTARY OF SMITH CANAL

has been prepared by, or under the direct supervision of, the following Registered Engineers:

NO. 32921 ★ EXP. 6/30/2010

Kjeldsen, Sinnock & Neudeck, Inc. Civil Engineers and Land Surveyors Post Office Box 844 711 N. Pershing Avenue Stockton, CA 95201-0844

TABLE OF CONTENTS

SECTION 1 INTRODUCTION	1
PURPOSE	1
SECTION 2 STUDY AREA	3
GENERAL	3
TOPOGRAPHY	3
SOILS	3
LAND USE	3
DRAINAGE AREA	3
SECTION 3 PLANNING AND DESIGN	8
GENERAL	8
STUDY PROCESS	8
LAND USE CONSIDERATIONS	8
DESIGN CONSIDERATIONS	8
SECTION 4 HYDROLOGY	9
METHODOLOGY	9
RAINFALL VOLUME	9
TIME OF CONCENTRATION	9
PUMPING FACILITIES	9
ANALYSIS	9
SECTION 5 CONCLUSIONS/RECOMMENDATIONS	13
GENERAL	13
IMPROVEMENTS	13

APPENDICES

Appendix A, FEMA Flood Insurance Rate Maps

Appendix B, Drainage subarea Characteristics

Appendix C, Pump Data

Appendix D, Hydrologic Analysis


SECTION 1 INTRODUCTION

PURPOSE

The purpose of this report is to investigate the extent of interior flood hazards within a portion of the City of Stockton that may be affected by Smith Canal. The area under investigation is the drainage tributary area of Smith Canal, as shown in Figure 1, "Location Map". The westerly portion of the study area lies within a Zone A designation per the FEMA Flood Insurance Rate Map, October 16, 2009 Map Number 06077C0455F. This map list the 100-year flood elevation for Smith Canal at elevation 10 feet (NAVD 88 datum). The easterly portion of the study area lies mostly within a Zone X designation with small portions in a Zone A designation per the FEMA Flood Insurance Rate Map, October 16, 2009 Map Number 06077C0460F. Both of these Flood Insurance Rate Maps are available in Appendix A, "FEMA Flood Insurance Rate Maps." This report analyzes the interior drainage flood hazards that may result from a 24-hour 100-year rainfall event.

A closure structure or gate is currently in design for the west end of Smith Canal this gate is intended to be closed during high tide events. An analysis of the closure structure and the operation of Smith Canal as a detention basin is beyond the scope of this analysis. A copy of the technical memorandum on the proposed closure structure is available in Appendix E, "Smith Canal Closure Structure Conceptualization."

High and low points within the streets of the study area can possibly create isolated flooding at the low points. However, a detailed analysis of the possible isolated flooding locations was beyond the scope of this report and is not a part of this analysis. Instead, this report focuses only on the ability to detain and evacuate the total runoff volume from within the drainage shed.



SECTION 2 STUDY AREA

GENERAL

The study area lies in the City of Stockton, San Joaquin County. The study area is the drainage shed tributary to Smith Canal. Figure 2 shows the approximate limits of the Smith Canal drainage shed.

For the purpose of this report, the total drainage shed studied is approximately 3,430 acres.

TOPOGRAPHY

In general, the existing ground surface topography within the drainage shed slopes from east to west 18.5 feet (NAVD 88 datum) at the intersection of California Street and Pine Street to an approximate elevation of -1.0 feet (NAVD 88 datum) at the intersection of Alpine Avenue and Wisconsin Avenue.

SOILS

A detailed soils investigation was beyond the scope of this report; however, the determination of the general soil characteristics was necessary to complete the hydrologic analysis. General soils information was obtained from the "Soil Survey of San Joaquin County, California" prepared by the United States Department of Agriculture (USDA) Soil Conservation Service.

The dominant soil classifications or map units within the District boundaries are Scribner-Urban land complex, Jacktone-Urban land complex, and Columbia fine sandy loam (drained). These soils have a general hydrologic group classification of Class "C," "D," and "B," respectively, according to the USDA NRCS Web Soil Survey.

SCS Curve Numbers (CN)

Land Use Description	Hydrologic Soil Group			
	A	В	С	D
Residential ¼ acre lot size	61	75	83	87
Commercial and Business Areas	98	98	98	98

LAND USE

The general land use within the drainage shed is primarily residential development ($^{1}/_{8}$ acre lots to $^{1}/_{4}$ acre lots) with some commercial development.

DRAINAGE AREA

The study area is divided into thirteen subareas, as shown in Figure 3, "Drainage Subareas," nine of the thirteen areas discharge from individual pump stations into Smith Canal. The remaining four subareas located in the southwest corner of the study area discharge by gravity into Smith

Canal. General subarea information is listed on Table 1 with specific data associated to each subarea drainage shed found in Appendix B, "Drainage Subarea Characteristics." None of the pump stations is currently equipped with a generator. Section 5 discusses the alternative means of providing power to the pump stations in the event of a power outage during a flood event. Detailed information about the pumps and pump stations is located in Appendix C, "Pump Data."

Table 1: Pump Station Data

			1	1
Drainage Subarea Designation	Drainage Subarea Name	Drainage Subarea Area (Ac)	Drainage Subarea Pump Station	Total Maximum Pump Station Capacity (gpm)
1	Buena Vista North	121.63	No. 1	5,500
2	Lake Drive	4.22	No. 2	2,700
3	Franklin Avenue	425.22	No. 3	15,260
4	Plymouth Road	90.44	No. 4	14,320
5	Gardena PS	54.65	No. 5	5,600
6	Moreing	35.92	No. 6	5,500
7	Yosemite Lake	1935.91	No. 7	129,500
8	Buena Vista South	477.47	No. 8	31,100
9	Ryde Ave.	167.1	No. 9	16,800
10	Kingsley Ave.	18.03	Gravity Discharge	
11	Pinetree Dr.	7.78	Gravity Discharge	
12	Occidental Ave	5.6	Gravity Discharge	
13	Louis Park	21.33	Gravity Discharge	

SECTION 3 PLANNING AND DESIGN

GENERAL

Presented in this section is an overview of the planning and design considerations for the interior drainage of the study area. The following sections of this report utilize this information to describe the hydrologic strategies and analytical process.

STUDY PROCESS

An analysis of the interior drainage areas that discharge into Smith Canal is necessary to determine whether street detention storage and existing facilities are sufficient to manage the runoff from a 24-hour, 100-year rainfall event.

LAND USE CONSIDERATIONS

As noted in Section 2 of this report, the land use of the subject area is primarily residential development with some commercial development. For the purposes of this report no other type of land use was considered in the analysis.

DESIGN CONSIDERATIONS

Rainfall runoff is considered as the only source of water entering the study area. This study will analyze the likely locations of street detention storage during a major rainfall event, the depth of detention storage within the streets is due to this event, and existing pumping facility capabilities.

SECTION 4 HYDROLOGY

A hydrologic analysis was performed to determine the runoff volume from a 24-hour, 100-year storm event. The thirteen subareas within the study area are in primarily residential areas. An analysis of City of Stockton GIS and aerial photographs shows that approximately twenty percent of these areas are composed of a network of residential streets. The street elevations are lower than those of the adjacent houses, so flooding would first occur in the street network before ponding to an elevation that would begin to flood houses or other buildings. Approximately one-half of the street networks could fill up with water to a depth of one foot before the water would inundate any buildings. The results of the hydrologic analysis were used to determine if the combination of street storage and the existing pump rates are adequate discharge rainfall runoff from a 24-hour, 100-year storm event into Smith Canal.

METHODOLOGY

The rainfall characteristic of the area is found in the Hydrology Manual for the San Joaquin County Department of Public Works. Using Hydraflow® Hydrographs 2008 and the NRCS Type 1 rainfall distribution unit hydrographs were established for each of the thirteen subareas. These unit hydrographs were then applied to a 24-hour storm duration obtained from the San Joaquin County Hydrology Manual (September 1997), producing a hydrograph appropriate for each subarea during a 24-hour, 100-year storm event. Data unique to each subarea such as acreage, soil group areas, paved area, SCS curve number, hydraulic length, and approximate time of concentration, are shown in Appendix B, "Drainage Subarea Characteristics."

Each pump station was modeled using a constant maximum pumping rate as shown in Table 1,"Pump Station Data," derived from the anticipated design pump capacity per the pump curves provided in Appendix C, "Pump Data."

RAINFALL VOLUME

Calculations for the runoff volume of each subarea were based on flow rates determined from hydrographs of a 24-hour, 100-year storm event, which were established as described above. Hydraflow Hydrographs determines the maximum runoff flow rate for a given watershed using a unit hydrograph for the rainfall depth of a 24-hour, 100-year storm event, watershed area, land use type and hydrologic soil groups, approximate watershed slope, and watershed hydraulic length.

TIME OF CONCENTRATION

The time of concentration was estimated to be the maximum time for rainfall to surface flow from the most hydrologically remote location to the street gutter, into the first storm drain inlet, and travel through the storm drain system to the point of concentration (pump station) for each subarea. The time of concentration for each subarea is shown in Appendix D, "Hydrologic Analysis."

PUMPING FACILITIES

As previously discribed, there are nine pump stations that discharge into Smith Canal, See Table 1 for specific pump data.

ANALYSIS

Results of the analysis are contained in Appendix D, "Hydrologic Analysis." A summary of the

results are shown in Table 2, "Storage and Runoff Volumes," which compares the total available street storage to the required 100-year runoff volume. As stated above, analysis of the available street network shows that approximately 20% of each of the subareas is composed of streets, as can be seen in Appendix B, "Watershed Characteristics." For the purposes of this report, it is assumed that one-half of the streets are capable of holding a depth of up to one foot of water before inundation will threaten buildings.

Table 2: Storage and Runoff Volumes

Drainage Subarea Designation	Drainage Subarea Name	Drainage Subarea Area (Ac)	Available Street Network Storage (Ac-ft)	Required 100-Year Runoff Storage Volume (Ac-ft), with Pumping Rate	% Storage Used, 100-year Storm, Existing Pump Rate	Available Storage Remaining (ac-ft)
1	Buena Vista North	121.63	12.0	10.6	88.3%	1.40
2	Lake Drive	4.22	0.4	0.06	15.0%	0.34
3	Franklin	425.22	42.0	41.0	97.6%	1.00
4	Plymouth	90.44	9.0	2.6	28.9%	6.40
5	Gardena	54.65	5.4	2.5	46.3%	2.90
6	Moreing	35.92	3.5	1.2	34.3%	2.30
7	Yosemite Lake	1935.91	193.0	158.7	82.2%	34.30
8	Buena Vista South	477.47	47.0	42.8	91.1%	4.20
9	Ryde Avenue	167.1	16.7	13.2	79.0%	3.50
10	Kingsley Avenue	18.03	1.8			
11	Pinetree Drive	7.78	0.8			
12	Occidental Avenue	5.6	0.6			
13	Pixie Woods	21.33	2.1			

^{1.} Required 100-year Runoff Storage Volume is the maximum storage volume required, which was determined using Hydraflow Hydrographs' reservoir modeling, which accounts for the time of concentration, the rainfall distribution, and the pumping rate at the point of outflow. The reservoir hydrographs are available in Appendix D, "Hydrologic Analysis."

As shown in the table above, all drainage subarea pump stations provide sufficient protection to the subareas they serve, minimizing flooding on the interior of the study area during a 100-year

^{2.} Existing pump rates provided are derived from the anticipated design pump rate at the time the pump was installed. Actual pump rates will vary.

storm event.
The discharge hydrographs from each drainage subarea (1 through 13) are combined to generate the Smith Canal inflow hydrograph. The volume of this inflow hydrograph is approximately 765 acre-feet. A plot of the Smith Canal inflow hydrograph is shown in Figure 4.

Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010

Hyd. No. 28

Smith Canal Combined

Hydrograph type = Manual Storm frequency = 100 yrs Time interval = 5 min Peak discharge = 465.01 cfs Time to peak = 645 min Hyd. volume = 765.475 acft



SECTION 5 CONCLUSIONS/RECOMMENDATIONS

GENERAL

This analysis demonstrates that the street network and existing drainage facilities as discussed above can adequately accommodate a 24-hour, 100-year storm event.

IMPROVEMENTS

Each pump station's electrical system should be improved to include a generator power receptacle with the appropriate switching gear. This will allow the connection of a portable generator during a power failure.

Appendix A, FEMA Flood Insurance Rate Maps

NOTES TO USERS

This map is for use in administering the National Flood Insurance Program. It doe not necessarily identify all areas subject to flooding, particularly from local drainag sources of small size. The **community map repository** should be consulted for possible updated or additional flood hazard information

To obtain more detailed information in areas where **Base Flood Elevations** (BFEs) and/or **floodways** have been determined, users are encouraged to consult the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or flood/plain management.

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stilwater Elevations table in the Flood insurance Study Report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction, and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood insurance Study

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to Section 2.4 "Flood Protection Measures" of the Flood Insurance Study report for information on flood control structures in this jurisdiction.

The projection used in the preparation of this map was Universal Transverse Mercator (UTM) Zone 10N. The horizontal datum was NAD83, GRS80 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same vertical datum. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at http://www.ngs.noaa.gov or contact the National Geodetic Survey website at http://www.ngs.noaa.gov or contact the National Geodetic Survey at the following address:

NGS Information Services NOAA, N/NGS12 NOAA, NINGS12 National Geodetic Survey, SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242, or visit their website at http://www.ngs.noaa.gov/.

Base map information shown on this FIRM was derived from multiple sources. This information was compiled from the U.S. Geological Survey, 2002, National Geodetic Survey, 2002, City of Lathrop, 1997, City of Manteca, Department of Public Works, 2001, and San Joaquin County Community Development Department, 2008. Additional information was photogrammetrically compiled at a scale of 1:12,000 from U.S. Geological Survey aerial photography dated 1989, 1993 and 2002.

This map reflects more detailed and up-to-date **stream channel configurations** than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data bables in the Flood insurance Study report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.


Corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.

Contact the FEMA Map Service Center at 1-800-358-9616 for information on available products associated with this FIRM. Available products may include previously issued Letters of Map Change, a Flood Insurance Study report, and/or digital versions of this map. The FEMA Map Service Center may also be reached by Fax at 1-800-358-9520 and their website at http://www.msc.fema.gov/.

If you have **questions about this map** or questions concerning the National Flood Insurance Program in general, please call 1-877-FEMA MAP (1-877-336-2627) or visit the FEMA website at http://www.fema.gov/.

ovisionally Accredited Levee Notes to Users: Check with your loca mmunity to obtain more information, such as the estimated level of protection community to obtain more information, such as the estimated level of protection provided (which may exceed the 1-percent-annual-chance level) and Emergency Action Plan, on the levee system(s) shown as providing protection for areas on this panel. To maintain accreditation, the levee owner or community is required to submit the data and documentation necessary to comply with Section 65.10 of the NFIP regulations by August 23, 2009, for the Fourteennile Slough Levee (east of Interstate 5) and the Rough and Ready Island Levees; August 23, 2010, for Levee P452 (along the horthwest boundary of Reclamation District 404), and March 30, 2010, for all other levees. If the community or owner does not provide the necessary data and documentation or if the data and documentation provided with the community of the community properly owners and residents are encouraged to consider model insurance and flood proficer protective measures. For more information on flood insurance, interested parties should visit the FEMA Website at http://www.fema.gov/business/nfip/index.shtm.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD

No Base Flood Elevations determined.

Base Flood Elevations determined.

Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood

Coastal flood zone with velocity hazard (wave action); no Base Flood determined.

Coastal flood zone with velocity hazard (wave action); Base Flood Elevations

OTHER FLOOD AREAS Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

OTHER AREAS

ZONE X Areas determined to be outside the 0.2% annual chance floodplain.
ZONE D Areas in which flood hazards are undetermined, but possible.

COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.

Floodplain boundary Floodway boundary Zone D Boundary CBRS and OPA Boundary

.....

Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities. Base Flood Elevation line and value; elevation in feet*

(EL 987) Base Flood Elevation value where uniform within zone; elevation in feet*

*Referenced to the North American Vertical Datum of 1988

(23) - - - - - (23) Transect line

600000 FT

DX5510~

97° 07' 30", 32° 22' 30"

Geographic coordinates referenced to the North American
Datum of 1983 (NAD 83), Western Hemisphere

476**
1000-meter Universal Transverse Mercator grid values, zone 10 5000-foot grid ticks: California State Plane coordinate system, zone III (FIPSZONE 0403), Lambert Conformal Conic Projection

MAP REPOSITORIES Refer to Map Repositories list on Map Index.

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

To determine if flood insurance is available in this community, contact your insurance agent or call the National Flood Insurance Program at 1-800-638-6620.



500 0 1000 2000 FEET 300 METERS



PANEL 0455F

FIRM

FLOOD INSURANCE RATE MAP SAN JOAQUIN COUNTY, CALIFORNIA AND INCORPORATED AREAS

PANEL 455 OF 950

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS: COMMUNITY

NUMBER PANEL SUFFIX SAN JOAQUIN COUNTY



MAP NUMBER 06077C0455F

EFFECTIVE DATE OCTOBER 16, 2009

Federal Emergency Management Agency

NOTES TO USERS

This map is for use in administering the National Flood Insurance Program. It doe not necessarily identify all areas subject to flooding, particularly from local drainag sources of small size. The **community map repository** should be consulted for possible updated or additional flood hazard information

To obtain more detailed information in areas where **Base Flood Elevations** (BFEs) and/or **floodways** have been determined, users are encouraged to consult he Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent nunded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Sillwater Elevations table in the Flood Insurance Study Report for this jurisdiction. Elevations shown in the Summary of Sillwater Elevations table should be used for construction, and/or floodplain management purposes when they are higher than the elevations shown on this FIRM. the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraufic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by flood control structures. Refer to Section 2.4 "Flood Protection Measures" of the Floonsurance Study report for information on flood control structures in this jurisdiction

The **projection** used in the preparation of this map was Universal Transvers Mercator (UTM) Zone 10N. The **horizontal datum** was NAD83, GRS80 spheroid INTERIOR (UTIN) ZURE LIVE. THE NOTZONTAL GARTUM WAS NAUSS, (SHSSB) spheroid. Differences in datum, spheroid, projection or UTIM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same vertical datum. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at http://www.ngs.noaa.gov or contact the National Geodetic Survey yet the following address:

NGS Information Services National Geodetic Survey, SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242, or visit their website at http://www.ngs.noaa.gov/.

Base map information shown on this FIRM was derived from multiple sources. This information was compiled from the U.S. Geological Survey, 2002, National Geodetic Survey, 2002, City of Lattrop, 1997, City of Manteca, Department of Public Works, 2001, and San Joaquin County Community Development Department, 2008. Additional information was photogrammetrically compiled at a scale of 1:12,000 from U.S. Geological Survey aerial photography dated 1989, 1993 and 2002

This map reflects more detailed and up-to-date **stream channel configurations** than those shown on the previous FIRM for this jurisdiction. The floodplains and foodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables in the Flood Insurance Study report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.

Corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.


Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels; community map repositively addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.

Contact the FEMA Map Service Center at 1-800-358-9616 for information or available products associated with this FIRM. Available products may include available products associated with this Firkin. Available products this include previously issued Letters of Map Change, a Flood Insurance Study report, and/ou digital versions of this map. The FEMA Map Service Center may also be reached by Fax at 1-800-358-9620 and their website at http://www.msc.fema.gov/.

If you have **questions about this map** or questions concerning the National Floor Insurance Program in general, please call **1-877-FEMA MAP** (1-877-336-2627) or visit the FEMA website at http://www.fema.gov/.

ccredited Levee Notes to Users: Check with your local community to obtain nore information, such as the estimated level of protection provided (which may more information, such as the estimated level of protection provided (which may exceed the 1-percent-annual-chance level) and Emergency Action Plan, on the levee system(s) shown as providing protection for areas on this panel. To mitigate flood risk in residual risk areas, property owners and residents are encouraged to consider flood insurance and floodproofing or other protective measures. For more information on flood insurance, interested parties should visit the FEMA Website at http://www.fema.gov/business/fifip/index.shtm.

Provisionally Accredited Leve Notes to Users: Check with your local community to obtain more information, such as the estimated level of protection provided (which may exceed the 1-percent-annual-chance level) and Emergency Action Plan, on the levee system(s) shown as providing protection for areas on this panel. To maintain accreditation, the levee owner or community is required to submit the data and documentation necessary to comply with Section 65.10 of the NFIP regulations by August 23, 2010, for Levee P452 (along the northwest boundary of Reclamation District 404 on panel 06077C045F) and March 30, 2010, for all other levees. If the community or owner does not provide the necessary data and documentation or if the data and documentation provided indicate the levee system does not comply with Section 65.10 the universities FeMA. necessary data and documentation or if the data and documentation provided indicate the leves system does not comply with Section 65.10 requirements, FEMA will revise the flood hazard and risk information for this area to reflect deaccreditation of the leves system. To mitigate flood risk in residual risk areas, properly owners and residents are encouraged to consider flood insurance and floodroprofing or other protective measures. For more information on flood insurance, interested parties should visit the FEMA Website at http://www.fema.gov/business/fifipindex.shhm.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD

The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, RR, A99, V, and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.

No Base Flood Elevations determined.

Base Flood Elevations determined.

Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood

Elevations determined.

Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined.

For areas of alluvial fan flooding, velocities also determined.

Special Flood Hazard Area formerly protected from the 1% annual chance flood by a flood control system that was subsequently decertified. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.

ZONE A99

Coastal flood zone with velocity hazard (wave action); no Base Flood Ele

Coastal flood zone with velocity hazard (wave action); Base Flood Elevations

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

OTHER FLOOD AREAS

Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

OTHER AREAS

ZONE X Areas determined to be outside the 0.2% annual chance floodplain.
ZONE D Areas in which flood hazards are undetermined, but possible.

COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.

Floodplain boundary
Floodway boundary
Zone D Boundary
CBRS and OPA Boundary

Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities. Base Flood Elevation line and value; elevation in feet*

(EL 967) Base Flood Elevation value where uniform within zone; elevation in feet*

*Referenced to the North American Vertical Datum of 1988

23 - - - - - 23) Transect line

97° 07' 30", 32° 22' 30" Geographic coordinates referenced to the North American Datum of 1983 (NAD 83), Western Hemisphere 1000-meter Universal Transverse Mercator grid values, zone 10 5000-foot grid ticks: California State Plane coordinate system, 600000 FT

DX5510×

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the Community Map History table located in the Flood Insurance Study report for this jurisdiction.



MAP SCALE 1" = 1000'

500 0 1000 2000 FEET

PANEL 0460F

FIRM FLOOD INSURANCE RATE MAP

SAN JOAQUIN COUNTY, CALIFORNIA AND INCORPORATED AREAS

PANEL 460 OF 950

SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS: COMMUNITY

SAN JOAQUIN COUNTY

MAP NUMBER

06077C0460F

NUMBER PANEL SUFFIX

060302 0460

EFFECTIVE DATE

Federal Emergency Management Agency


Appendix B, Drainage subarea Characteristics

Drainage subarea Characteristics

Ü				Time of			
				Conc.	Frequency	SCS Rainfall	Rainfall
Drainage Subarea Name	Area (Ac)	Composite CN	Length (ft)	(min)	Storm	Distribution	Depth (in)
Buena Vista-1	121.63	89.6	3950	65.8	1%	Type 1	3.51
Lake Drive-2	4.22	90.1	925	15.4	1%	Type 1	3.51
Franklin-3	425.22	88.8	9300	155.0	1%	Type 1	3.51
Plymouth-4	90.44	84.6	4225	70.4	1%	Type 1	3.51
Gardena-5	54.65	86.2	3000	50.0	1%	Type 1	3.51
Moreing-6	35.92	85.2	3200	53.3	1%	Type 1	3.51
Yosemite Lake-7	1935.91	94	15800	263.3		Type 1	3.51
Buena Vista-8	498.15	95	7000	116.7	1%	Type 1	3.51
Ryde Avenue-9	167.1	95	4600	76.7	1%	Type 1	3.51
Kingsley Avenue-10	18.03	94	1400	23.3	1%	Type 1	3.51
Pinetree Drive-11	7.78	94	1500	25.0	1%	Type 1	3.51
Occidental Avenue-12	5.6	95	1400	23.3	1%	Type 1	3.51
Pixie Woods-13	21.33	93	600	10.0	1%	Type 1	3.51


Appendix C, Pump Data

Pump Station 1 Subarea: Buena Vista North




Pump Station 2 Subarea: Lake Dr. Pump Station 3
Subarea: Franklin Dr.











Pump Station 4
Subarea: Plymouth Dr.











CASCADE PUMP COMPANY

10107 South Norwalk Boulevard • PO Box 2767 Santa Fe Springs, California 90670-0767

MC1206DD4


DATE 08-91

SUPERCEDES


NEW ISSUE


MFC

1175 RPM



Pump Station 5
Subarea: Gardena St.





Pump Station 6
Subarea: Moreing St.

AppB-Pump_Data

Pump Station 7 Subarea: Yosemite Lake

- 2. Gears shall be of the spiral bevel type, case hardened, and lapped together to insure quiet operation. Gears shall be designed with a service factor to equal or exceed 1.50 on speed decreasing ratio and shall be rated at 150 HP at 580 RPM.
- 3. Bearing and gears shall be lubricated by means of a force feed system. The oil pump shall deliver an adequate supply of oil by spray jet to the gear mesh and by oil passage to the upper bearings, from which the oil may be returned by gravity through the pinion bearing back to the pump. An oil sight glass shall be mounted on the gear housing to indicate oil level.
- 4. The right angle gear drive shall be an air cooled type not requiring auxiliary heat exchanger equipment.
- 5. The right angle gear drive shall be designed to withstand the thrust of the propeller pump and also momentary up thrust.
- c. The right angle gear drive shall be furnished with three (3) copies of complete testing, operating and maintenance instructions and replacement parts lists for the unit furnished.
- .03 Low Lift Propeller Pump (Four (4) Required)

The storm water pjmps shall be as outlined below and shall be Johnston Pump Company Model 30 PO, Byron Jackson 30 HS, or approved equal.

a. Pump Performance Data

Design Capacity, GPM 27,000.
Design Head, TDH 15'
Min. Bowl Eff. at Des. Hd., % 85.5% 94
Max. HP at Des. Head 125

Secondary Capacity, GPM	31,000
Secondary Head, TDH	13'
Min. Bowl Eff. at Sec. Hd., %	85%
Max. HP at Des. Head	120
Max. Submergence	70"
Max. Syn. Speed, RPM	585
Size Column & Disch.	36"
Min. Lineshaft Size	2-3/16"

The total pumping head includes losses in the pump, discharge column, suction pipe and bell.

It is noted that the pumps will be rated at the principal design condition only and that the other points indicated are for guide purposes indicating ranges of operation in which the units must operate satisfactorily.

The term "submergence" shall be understood to be the vertical distance from the bottom of the suction bell to water surface in the sump. The term "total dynamic head" shall be understood to mean the sum of the static head, the friction head in the discharge elbow and discharge pipe, and discharge velocity head.

- b. Pump Column and Discharge Elbow: The vertical pump supporting column and discharge elbow shall be made of welded plate steel with 5/16" wall thickness. The discharge opening shall be plain end, fitted with a Dresser type coupling suitable for connection to the discharge pipe. The discharge elbow shall be of the long-sweep type consisting of at least 3 sections, and shall be above base discharge.
- c. Base Plate: The pumping unit shall be suspended from a steel base plate 1-1/2" thick to support the weight and thrust of the complete unit. The oil tube nut shall be located on or above

- the base plate to provide for easy maintenance. The dimensions of the base plates shall be 66" square.
- d. Bowls: The suction bell and pump bowl shall be made of close-grained Class 40 cast iron and shall be designed for easy removal of the impellers and bearings. The suction bell shall have a flared inlet designed to reduce entrance losses and a sufficient number of vanes to support the lower guide bearing as well as to sustain the weight of the impeller and pump shaft when dismantling the pump. The bowl shall have a replaceable bronze liner.
- e. Impellers: The pump impeller shall be made of bronze (ASTM B62-52) and shall be fastened to the shaft in such a manner as to be removed readily. They shall be balanced statically and dynamically to reduce vibration and wear.
- f. Shaft: The shaft of the pumping unit shall be of ample size to operate without objectionable distortion or vibration at maximum speed in both the forward and reverse direction of rotation. The pump-bowl shall be made of 416 stainless steel and the line shaft shall be made of carbon or alloy steel. The shaft couplings shall be of the threaded type. Provision shall be made at the top of the motor shaft for adjusting the elevation of the impeller with reference to the bowl.
- g. Bowl Bearings: The pump shall have a main bronze bearing immediately above the impeller, and a lower bronze bearing below the impeller. The bearing below the impeller shall be grease lubricated from above the base plate.

- h. Lineshaft Bearings: The oil-lubricated lineshaft bearings shall be protected from water and foreign matter by the Schedule No. 80 steel enclosing tube. A shaft seal shall be provided immediately above the top propeller. By-pass ports to drain excess oil from the shaft enclosing tube shall be provided above the seal. All bearings shall be easily replaceable, and spaced not more than five feet apart.
- i. Lubrication: The pump shall be oil-lubricated and equipped with a solenoid operated lubricating system which shall supply lubricant to each lineshaft bearing. The solenoid-operated oiler shall be designed for outdoor operation and shall have a metal oil reservoir with a capacity of not less than 1 gallon.
- j. Coating: Below the baseplates, the pumps shall be coated inside and outside with a 2-coat application of bitumastic.
- k. Operational Data: The successful bidder shall submit two copies each of dimension prints; performance curves showing head-capacity, pump efficiency, and brake horsepower; and the pump manufacturer's published single stage book performance curves which show compliance with these specifications.
- .04 Electric Powered Summer Pump

 The summer pump shall be as outlined below:

a. Pump Performance Data

Maximum Horsepower	40	
Pump Head	18.5'	
Minimum GPM	5,500	
RPM Max.	1,200	97
RPM Min.	.875	
Pump Eff.	80%	

The total pumping head includes losses in the pump, discharge column, suction pipe and bell.

b. The applicable provision set forth in Section C, 5.03, b,
c, d, e, f, g, h, i, j, and k shall apply to the construction of the pump.

The pump column and discharge elbow shall be twenty (20) inches in diameter and shall be constructed of 1/4" thick welded steel plate.

The column length, location of the discharge and the base plate size shall be as shown on the plans.

c. The motor to operate the summer pump shall be a 40 horsepower electric vertical ball-bearing; hollow-shaft; normal
thrust; squirrel cage induction type for continuous
operation; with a temperature rise not to exceed 40 degrees
C. on 208 volt, 3 phase, 60 hertz current. RPM rating shall
be adjusted to match the demands of the particular pump
supplied.

The motor shall be designed for across the line starting.

The motor shall be shielded, drip-proof with back spin protection, and fully guaranteed in writing for these conditions.

Momentary up-thrust protection shall be provided by proper bolting to the base.


Legion Part of Smith Caral							
ORDER NO. D - 36940							
Sheet No. / of / Sheets No. Units A. MCS 4 J-P / Extra Copies - PURCH. P.H.L / FACTORY	V						

PL COMPANY P. O. SOX 1300 LA PUENTE, CALIF. 91747 200 NOBTH PUENTE AVE. CITY OF INDUSTRY, CALIF.	PROPELLER/MIXED FLod ORDER ACKNOWLEDGEMENT Sheet N Extra	to. / of / Sheets No. Units 4 Copies - PURCH. PHL / FACTORY / P.O. No. 5320
1 CGOOLDESON	GPM 2/000	REFERENCE No.
P.O. Box 910	STATIC	QUOTE No
STACKTON CALIF.	FIELD	SCHEDULED SHIPPING DATE 9-8-72
	Loss	SHIP AS COMPONENTS
S CITY OF STOCKTON	LAB TDH 15 86.5 1/8	SHIP ASSEMBLED LESS MOTOR
AMERICAN LEGION PACK	RPM 600	CREDIT APPROVAL HO By,
STOCKTON, CA.		TERMS
	WATER FUNDES	Tollect 19 20 21 22 23 24 25 (2) 27 28 29 30 31 Agr. Pws. (Num)
JOB NAME AMERICAN LEGION PARK	or Rep.	Driver
L& B P.O.No. VENDOR		
QUANTITY OF Pump Total	RIPTION CODE A1-	260 The last of th
GEAR DRIVE - MIR. RANDOLPH Model	20 Ratio 3, 1	Decreaser
Standard NRR Yes BX 23/16 BD	20 00 241/2	
CC//C Cooling Input Shaft CW		and the second s
3 3 COMPLETE TESTING OPERATING & MAIN	TENANCE INST. & PAUTS LIST	
BANEL STARTER - Mfr. HP.	VPHTyp•	
PB 3rd Leg TDR Fuses	VBHP Heaters	
HOA SB Thermatectors Fusetrons L	8P.3GP	A STATE OF THE PARTY OF THE PAR
1 A Pedestal Height	-	1 .
Pedestal Height Ped. & Elbow Loth. Surf. Elbow D 7-75/8" Loth D36940-	Part Number Encl. Shaft Electromatic	
Surf, Elbow Der Loth 26740-1	B & Disch. Out	3 2 "
Elbaw Figid. ASA Tension Nut S	F & Disch, Down	
Tube 3 ½" Shaft 2 3/16 X 32	3/4 Leth. Bell Lip /	5/10"
The state of the Second New	Lgth. Bell Lip /s	
	Max. Cal. Lgth. L.S. Ber	aring 3'-4"
7= 28= FT. COLUMN 36 Pipe 35 Tube 27 Shaft Elbow Loth. Part No	3ec110n	Total Ligth.
		Lgth.
Other Col. Loth. Part No	With Top Lineshaft 23/16 x 5-4= Shaft Proj. Below Dr. Base 7"	Lgth.
	Other Inner Col. Assem.	Lgth.
24 96 Col. Flg. Bolts/Nuts 3/4 x 3	Bot. Inner Col. Assem 5x31/2 Size/O	Lgth.
1 4 BOWL ASSEMBLY - Type 30 Stage Stage Propeller 13 OUFE 12 BACK Tube	Basket Strainer Basket Strainer Proj. 7" Shaft 2.3// Proj.	20"
Impeller DYNAMIC, BALHINGE	PRIP & DISCH BOWL LS 9824	
SUCTION PECC 65 9394	(MARKED PRINT)	
OVERSIEE KILE FOT 6650 X1/12	-HOD- MOTE-	72/24
	SHIP WITH ORDE	FET.
	BAT REG. SUCT RELLI-L	03/6940-1
	1 O.D. COVER TUBE É O.D. B. LAB	
MINI WALL THICKNESS &	(/-	
	F CLASSAO C.I. ST DIST.	* 1
2/CE3 0/3/1		
		•
		Commission
Performance Winess With Cost Driver Notify Sales Deat.	Days Before Test Pump Data Final 🔀 Cu	rive 4 U Dim. Print 4 Assembly 2
Performance Witness With Cust. Driver Notify Sales Dept. TESTS Factory St. Certified Elbow Column C		mended Spore Parts Literature A Menuels
Hydrostatic Witness PSI PSI PSI	PSI Documents: Invoices	Packing List Bill of Lading Other

Verii-Line

PROPELLER PUMP





PLOTTED BY: KINE DATE SINGLE S

OPERATING AND MAINTAINTANCE INSTRUCTIONS FOR RANDOLPH PROPELLER PUMP DRIVES MODELS 12, 16, 20, 24 AND 30

.ICATION:

Use a high grade turbine oil, preferably with rust and oxidation inhibitor.

AMBIENT TEMPERATURE (°F)	10°40°	30°60°	50°125°
AGMA NUMBER	3	4	5
VISCOSITY RANGE SUV	490-700	700-1000	80-105
	SUV @ 100°F	SUV @ 100°F	SUV @ 210°F
GULF	HARMONY C	HARMONY 69	HARMONY 97
HUMBLE	TERESSTIC 52	TERESSTIC 65	TERESSTIC 85
TEXACO	REGAL E	REGAL F	REGAL G

The above list of oils is given only as the type of oil. There are many other suitable turbine oils.

Change oil at least every 1000 to 1500 hours of operation. If drive is operated intermittently less than 1000 hours in a season run of two or three months, change oil at end of that period of operation to eliminate the water formed in the gear case due to condensation. Frequency of change depends upon the rate of water condensation in the drive.

To drain the oil, remove the drain plug which is located near the bottom of the drive. The oil should be maintained at or near the red line marked on the sight gage glass.

COOLING:


Models 20, 24, and 30 are air cooled. Models 12 and 16 do not require extra cooling. Therefore very little maintainance is required on the heat exchanger. In dusty locations the heat exchanger should be cleaned once each year to ensure peak cooling. To clean remove cover and fan blade. Scrub inside fins and parts with a good cleaning solvent.

REPAIRS:

If possible repairs should be made by the factory. Any ratio changes should be made by a qualified mechanic. Shims will be necessary to obtain proper gear tooth contact and back lash.

Consult factory for recommendations if repairs are necessary. So sure to give serial number of drive when ordering parts.

RANDOLPH MANUFACTURING COMPANY 1110 N. AVENUE T. BOX 5306 LUBBOCK, TEXAS 79417



PARTS LIST

- I COVER PLUG WITH GASKET \$ 250 TFC
- 2 COVER R 2021 A
- 3 HEAT EXCHANGER R 2021
- 4 CLUTCH R 2009 A
- 5 CAP SCREWS & LOCK WASHERS \$ X 14 (8 REQ'D)
- 9 OVER GEAR SPACER
- 10 UNDER GEAR SPACER
- 11 GEAR KEY 4 X 2 X 3 1 1 12. PINION KEY 2 X 8 X 2 4 (WHEN REO'D.)
- 13. HORIZONTAL SHAFT KEY \$ X \$ X 4
- 14 GEAR AND PINION SET (SPECIFY RATIO)
- 17 NON-REVERSE CLUTCH HOUSING R 2055
- 18. CAP SCREWS & LOCK WASHERS \$ X 14 (4 REQ'D.)
- 21 THRUST BEARING CARRIER R 2003
- 26 CAP SCREWS & LOCK WASHERS \$ X 14 (8 REQ'D) 27. CAP SCREWS & LOCK WASHERS & X 4 (8 REQ'D.)
- 28. CAP SCREWS & LOCK WASHERS 7 X 12 (6 REQ'D.)
- 30. HORIZONTAL SHAFT H 2021 (WHEN REQ'D.)
- 31 OUTBOARD BEARING 9321/9380
- 32 INBOARD BEARING HM 212011 / HM 212044


- 36. INSPECTION PLATE -R 306
- 37. GASKET G 306
- 38. SHIM G 2055
- 39 FAN R 2024
- 42. OIL PUMP R 1608
- 43. STANDPIPE R 495
- 44 SHIMS G 2000
- 45. SHIMS G 102
- 46. SHIMS G 52
- 47. RADIAL BEARING 672/687
- 48. MAIN CASE R 2000
- 49. VERTICAL SHAFT V 2001
- 52. OIL LINES & FITTINGS
 - MALE HALF UNION 1X8 FLARE NUT &
- OIL LINE 1K X 15 54. THRUST BEARING 90744 / 90381
- 55. SIGHT GAUGE CASTING R 61
- ALLEN HEAD CAP SCREW & X I (2 REQ'D.) 56. SIGHT GAUGE GLASS R 64
- 57. SIGHT GAUGE GASKET G 53

- 60. OIL SEAL 55511 S
- 63. ROUND SIGHT GAUGE
- 64. DRIVE PLATE R 2006
- 65. DOWELL PINS 1 X 14 (2 REQ'D.)
- 66 DRIVE PLATE KEY \$ X 4 X 2
- 67 DRAIN PLATE WITH 2 3"PLUGS R 2022
- 70. SNAP RING 5000-350 (2 REQ'D.)
- 71. GEAR HUB R 2017
- 72. DRILLED HEAD CAP SCREWS \$-18 NF X 134(12 REQ'D.)
- 73. CAP SCREWS & LOCK WASHERS 16 X 12 (6 REQ'D.)
- 74. INBOARD BEARING BUSHING R 2011 (WHEN REQ'D.)
- 75. CAP SCREWS & LOCK WASHERS 5 X I (6 REQ'D)
- 77. INBOARD BEARING CARRIER R 2054
- 85. PIPE PLUG 2" N.P.T.

REV. 11-21-69

MODEL 20 **ASSEMBLY** Date 10 - 18 - 67 Dr By

RANDOLPH MANUFACTURING CO. LUBBOCK --- TEXAS



	11	АК	l	1											1			1 1
MODEL 20	20	13.501	5-11	242	29	41	18	123	18	45	318	13	21/2	184	1-16	143	5 X 5 8 X 16	2.249
MODEL 24	242	13.501	5-11	314	383	7	14	148	224	6	33 34	13	31/2	23	13 16	143	3 X 3	2.937

CUSTOMER R. Goold & Son City of Stockton ADDRESS ____American Legion Park Pumping Plant CUSTOMER ORDER NO. 5820 MODEL _______ 20 HP _____ 200 RATIO _____ 3:1 INPUT RPM 1800 OUTPUT RPM 600

CLUTCH BORE "BX" 2-3/16" KEYWAY "X"

TAP SIZE "BY" "BZ" B.C.

> CERTIFIED DIMENSION PRINT MODEL 20 & MODEL 24 Dr By PAJ Date 11-4-69

RANDOLPH MFG. CO. LUBBOCK -- TEXAS

Pump Station 8 Subarea: Buena Vista South


BUENA VISTA & SMITH CANAL
(STORM - PUMP STATION)
(la) WAUKESHA GASOUNE ENGINE MODEL 195GK SIZE 41/8 X 4
SER. # 1019018 LOT 564 SPEC, 195GK53-J (16) U.S. MOTORS (ELECTRIC MOTOR) H.P. 50 PH. 3 SER. # HZ4= 1131476 VOLTS AAO TYPE CFL 60 CYCLES
720 R.P.M. 69.5 HI VOLTS (AMPS) FRAME 587-P BEARINGS: UPPER 7-7226 GM LOWER- 1-6220 F CODE B DESIGN
LOWER- 1-6220 F CO (IC) TOHNSON GEAR & MFG CO PIGHT ANGLE DRIVE. SER # 28360 HEILO RATIO 5-2 BHP. 36 @ 720 P.P.M. (VERT SHAFT)
(H) FAICBANKS - MORSE PUMP (H) FAICBANKS - MORSE PUMP FIG. 6310 PROPELLER PUMP 12,000 GPM, 24" DISCHARGE FACTORY SER, # PW 6069 PUMP SIZE ZA- STAGES PROP. A5 A357-3 R.P.M., 720
(STELLING PUMP CO.)
MODEL 12 FAIL FRAME 6306 MODEL 12 FAIL FRAME 6306 VOLTS 220/440 FL AMP. 101/50,5 Z PH. CYCLES 60 SPEED FULL LOSD 1175 40 H.P. SEP. # 5421894 8,000 GAM
(2b) STERLING PUMP Drive # 8823? PUMP# 8823
(30) GENERAL ELECTRIC PUMP HP 5
(40) 75 HP MOTOR? CHECK
(46) CASCADE PUMP SER # 3076


INSTALLATION, **OPERATION AND MAINTENANCE INSTRUCTIONS**

Buena Vista 10-9-96

8000

PROPELLER PUMPS





14" 8312 1170 RPM 1 STAGE


COLUMN
16"
FABRICATED
STEEL ELROW
1-1:2"
LINESHAFT
2-1:2"
ENCLOSING

TUBE

DATA	VALUE			
PUMP SHAFT DIAMETER	1.6875 IN.	1.6875 IN.		
MAXIMUM SPHERE SIZE	2.25 IN.			
Ki (THRUST FACTOR)	46 LBS./FT.			
Ka (TOTAL ROTOR WEIGHT)	45 LBS.			
Ks (SETTING CONSTANT)	5.5 LBS./FT.	5.5 LBS./FT.		
WK'	7.1 LBS. FT. ²	7.1 LBS. FT. ²		
BOWL ASSEMBLY WEIGHT	425 LBS.	425 LBS.		
EYE AREA: PROPELLER NO. A-310-F	92.0 SQ. IN. 4 VANE			
PROPELLER NO. A-311-T	92.0 SQ. IN. 3 VANE			
PROPELLER NO. A-312-T	92.0 SQ. IN. 3 VANE			
PROPELLER NO. A-313-1	92.0 SQ. IN. 3 VANE			
PROPELLER NO.				
PROPELLER NO.				


HYDRAULIC PERFORMANCE IS CONTINGENT ON FURNISHING THE PUMP WITH SPECIFIED AMOUNT OF CLEAR, FRESH, NON-AERATED WATER NOT TO EXCEED 85° F.

PUMP PERFORMANCE SHOWN IS BOWL ASSEMBLY WITH 10 FEET OF COLUMN INCLUDING A STANDARD ABOVE GROUND DISCHARGE ELBOW. ADDITIONAL COLUMN LOSSES SHOULD BE ADDED WHEN SETTINGS ARE DEEPER THAN 10 FEET AND/OR FOR OTHER DISCHARGE ARRANGEMENTS.



*This value is the minimum submergence required to prevent vortexing only. This value may need to be increased to provide adequate NPSHA.






24" 8211 705 RPM 1 STAGE

24"
COLUMN
24"
FABRICATED
STEEL ELBOW
1-15/16"
LINESHAFT
3"
ENCLOSING
TUBE

DATA	VALUE	=		
DATA	VALUE			
PUMP SHAFT DIAMETER	2.1875 I	N		
MAXIMUM SPHERE SIZE	3.75 IN	J		
Kt (THRUST FACTOR)	150 LBS.	/FT.		
Ka (TOTAL ROTOR WEIGHT)	165 LB	S.		
Ks (SETTING CONSTANT)	10.0 LBS.	10.0 LBS./FT.		
WK ²	67 LBSFT. ²			
BOWL ASSEMBLY WEIGHT	1300 LBS.			
EYE AREA: PROPELLER NO. A-158-3	247.4 SQ. IN.	3 VANE		
PROPELLER NO. A-357-3	247.4 SQ. IN.	3 VANE		
PROPELLER NO. A-357	271.7 SQ. IN.	3 VANE		
PROPELLER NO. A-163-A-3	247.4 SQ. IN.	4 VANE		
PROPELLER NO. A-163-A	271.7 SQ. IN.	4 VANE		
PROPELLER NO.				

HYDRAULIC PERFORMANCE IS CONTINGENT ON FURNISHING THE PUMP WITH SPECIFIED AMOUNT OF CLEAR, FRESH, NON-AERATED WATER NOT TO EXCEED 85° F.

PUMP PERFORMANCE SHOWN IS BOWL ASSEMBLY WITH 10 FEET OF COLUMN INCLUDING A STANDARD ABOVE GROUND DISCHARGE ELBOW. ADDITIONAL COLUMN LOSSES SHOULD BE ADDED WHEN SETTINGS ARE DEEPER THAN 10 FEET AND/OR FOR OTHER DISCHARGE ARRANGEMENTS.



^{*}This value is the minimum submergence required to prevent vortexing only. This value may need to be increased to provide adequate NPSHA.

Storling 40hP pin, Storype 8000 16 215change

BRAKE HORSEPOWER Subbargance . (Fi.) [ExE [ဗေဒဘ စွဲ 100 50 2.5 0 Stage Pump. Stage Pump. R.P.M. MODEL P16A Performance to clear Fresh Water (4.70° F. Submergence shown from bottom of suction bell Pump efficiency $\pm\ 2\%$ 14000 Based on T- 3879 1170 12000 CAPACITY IN U.S. GALLONS PER MINUTE 10000 (Supersedes NEW 0009 4000 Impeller L-5719 9/13/82 L-5718 BRZ 2000 Issue Date 1-3725 -3725 Bowl TOTAL DYNAMIC HEAD IN FEET

TOTAL DYNAMIC HEAD IN FEET 5.0 25.0 30.0 C-8780 Mach. No. Diameter Patt. No. Material

+ Curash 15hp


SUBMERGENCE (FL.) BBAKE HORSEPOWER 50 15 0 Stage Pump. Stage Pump. 0 700 R.P.M. | MODEL M 2 2 220.00 M22 Performance for Model BASED ON T-3795, T-3795-1 20000 18000 CAPACITY IN U.S. CALONS PER MINUTE PUMP PRIME (Supersedes C-5597 L 12000 L-5469 --5485 Impeller BZE. 10000 9-1-84 II - 2695H-2695 Issue Date C.I. 8000 Bowl 35 30 20 25 10 2 0 Patt. No. Mach. No. Diameter Material 101AL DYNAMIC HEAD IN FEET C-89

form 853

+

Pump Station 9 Subarea: Ryde St.

SMITH CANAL & RYDE	
(STORM - PUMP STATION)	
(1a) U.S. MOTORS # Z FLECTRIC POMP 20 HP 3 PH	
#2 FLECTRIC POMP 20 HP 3 PH	60 cycles
(S) & FRAME A 286UPY 30% UPTHRUST	
MOTO TYPE RU DESIGN B CODE G	
VOLTS 230 - 50 AMPS 1800	R.P.M
460 - 25 AWIPE	
BEARNAS & LIPPER - 1-7218BY	
Lower - 1-62/07	
S.F. 1.15 SER# H-1019803	
(IL) FAIRBANKS - MORSE PUMP	
STAGES SIZE 8 MODEL 6360	
IMP B-1431-T	
SER. # KZMZ037266 PPM 1770 GF	2900
#1 (Za) U.S. MOTORS (HOLDSSHAFT)	
ELECTRIC MOTOR 20 HP 3 PH	60 cderes
FRAME A 286UPY 30% UPTHRUST	
TYPE RU DESIGN B CODE G	
VOLTS -AMPS (SEE ABOUT)	
BEARINGS (SEE ABOUE)	
5ER. # H-1019802	
(26) FAIR BANKS - MORSE FUMP	
(SEE ABOVE)	
SER. # KZM2037265	



18 hear

At least 30 days prior to the designated completion date of the contract, the contractor shall submit to the Engineer for approval the proof of a complete maintenance and operations manual for the pumping plant.

At least 5 days prior to the designated completion date, the contractor shall furnish to the Engineer four (4) copies of the completed approved maintenance operations manual.

The manuals shall be hard cover loose-leaf notebook type with all inserts covered by clear plastic covering.

The manuals will include a written operation description outlining overall plant operation sequences, including initial control settings along with standard publications on all major items including wiring diagrams, dimensional drawings and performance curves. Bulletins and catalogs shall be furnished on <u>all</u> accessory equipment.

3.11 STORM WATER PUMPS AND MOTORS

3.11a Scope of Work

The work includes all labor, material and equipment required for the installation of a storm water pumping station for this project in strict accordance with these specifications and as shown on the applicable drawings, and shall be subject to the terms and conditions of the contract. Any incidental work not shown or specified which can be reasonable inferred or taken as belonging to the work necessary to provide the system described or shown shall be the responsibility of the contractor.

3.11b The Work Includes

- (1) Furnish and install one (1) Layne and Bowler 20P24 propellor pump, 880RPM with 60 H.P. motor.
- (2) Furnish and install one (1) Paco Lift

 Type QDN612-11, submersible non-clog

 pump system, 870RPM with 5 H.P. motor.

damage to other materials, furnishings, equipment or premises caused by such defects during this period, if, in the opinion of the Engineer, said defect is due to imperfection of material or workmanship.

3.11f Care and Cleaning

All broken, damaged or otherwise defective parts of his work shall be repaired or replaced by the contractor, at his expense, and the entire work left in a condition satisfactory to the Engineer. At completion, the contractor shall carefully clean and adjust all equipment, and trim which are installed as part of his work and the systems and equipment left in satisfactory operating condition. Piping shall be drained and flushed to remove grease and foreign matter.

All surplus materials and debris resulting from his work shall be cleaned out and removed by the contractor, as directed. This includes surplus excavated material.

3.11g Testing

The complete pumping unit shall be tested under full load conditions and all adjustments shall be made to insure proper operation. The test shall be made to insure proper operation and shall be conducted at a date after the installation has been complete and as requested by the Engineer. Said test will be requested when there is sufficient water in the system to conduct the test.

3.11h Propellor Pump

The main pump shall be a Layne and Bowler propellor pump, Model 20P24, 880 RPM, or an approved equal meeting the following performance requirements:

Total Head	Capacity	Bowl Efficiency	<u> Horsepower</u>
18.5 ft.	10,000gpm	80%	59
16.0 ft.	11,000gpm	84%	55
13.4 ft.	11,700gpm	84%	51

performs in accordance with the design requirements. Such tests shall be certified in writing by a Registered Civil Engineer. Passing certified test results shall be supplied the Engineer prior to installation of pumps.

The pump impeller shall be made of bronze (ASTM B62-52) and shall be fastened to the shaft in such a manner as to be removed readily. They shall be balanced statically and dynamically to reduce vibration and wear.

The shaft of the pumping unit shall be of ample size to operate without objectionable distortion or vibration at maximum speed in both the forward and reverse direction of rotation. The pump-bowl shall be made of 416 stainless steel and the line shaft shall be made of carbon or alloy steel. The shaft couplings shall be of the threaded type. Provision shall be made at the top of the motor shaft for adjusting the elevation of the impeller with reference to the bowl.

The pump shall have a main bronze bearing immediately above the impeller, and a lower bronze bearing below the impeller. The bearing below the impeller shall be grease lubricated from above the base plate.

The oil-lubricated lineshaft bearings shall be protected from water and foreign matter by the Schedule No. 80 steel enclosing tube. A shaft seal shall be provided immediately above the top propeller. By-pass ports to drain excess oil from the shaft enclosing tube shall be provided above the seal. All bearings shall be easily replaceable, and spaced not more than five (5) feet apart.

The pump shall be oil-lubricated and equipped with a solenoid operated lubricating system which shall supply lubricant to each lineshaft bearing. The solenoid operated oiler shall be designed for outdoor operation and shall have a metal oil reservoir with a capacity of not

3.11k Control Panel

See Electrical, plans and specifications, for full operational and equipment requirements.

3.12 PUMP DISCHARGE PIPES

3.12a Sump Pump Pipe

Sump pump discharge pipe shall be cement lined ductile iron pipe with threaded companion flanges in accordance with AWWA C115. Fittings shall be flanged, AWWA C110. Swing check shall be designed for sewage flows.

3.12b Storm Pump Discharge Pipe

Pump discharge piping shall be welded steel pipe, coated in conformance with AWWA C203, coal tar enamel coated with 15 pound felt and Kraft paper outside. The twenty-four (24) inch diameter pipe shall be one-quarter (1/4) inch, minimum, thick steel pipe.

All bends shall be shop fabricated to AWWA standards prior to coating and wrapping. Pipe sections shall be made up in longest units possible to hold field welding to a minimum.

Fieldwelds on discharge pipe shall not exceed five (5). Field repair of coating and wrapping shall meet or exceed original.

3.12c Siphon Breaker

Siphon breaker shall be Harris size C-7 as manufactured by Sacramento Pipe Works or an approved equal.

3.12d Cut Off Wall

Cut off wall shall be standard size, clamp type, steel, 12 gauge minimum, and soil proofed.

3.12e Riprap

Levee protection material shall be Light Class conforming to Section 72 of the Standard Specifications and placed on prepared slope area by Method B.



AURORA PUMP AUNIT OF GENERAL BIGNAL

800 AIRPORT ROAD+NORTH AUHUHA, ILLINOIS+60542

NO. OF PRINTS

FOR APPROVAL


FINAL


		•				
\LES 0	FFICE:	SANFRI	NC15CO		PO#	t
*	RDER NUMBER	: 815-7				
				RYDE A	UE PUMP	STATION
			WATER	akkent gille gille mangille på sigst some Eld blidd upspendelig littlessenne		
		DPW S	TOCKTON			
	R:	1. JAYNA	FRICIEN	e com a marina de um est per um este per un la		
	n		mande and the State of Santa State of S	nd den grad grad de spe for jumpl, des et menskele, gleiche der ich zu verfer jele diestjeste die verbestliche	PO #	+ 7/18/85 LTK.
			ningamusuu Air, ugama qiydhariy i 12 78 l d-j-ii da qiqin qoya qor abbadi, irda da shi ninabaniya	elemente e dem se sta este menoral menorale e petitor sel simpo nej my periodo prime e consistenciente.	FO T	- myazara
AEPENENCE						
			PUMP	_		
,	NUMBER	4			1,000 GPM	
	OF UNITS	ZOPZ4	_ SIZE SEE C	<i>URVE</i> GPM <i>Se</i>	EE CURVE TOH .	<i>880</i> rpm
101171	DISCHARGE		COMPANION		SEPARATE (") BASEPLATE	ソンハ SOL. OILER
11/4669	HEAD _		FLANGE _	مناسبته والمراجعة والمراجعة والمراجعة والمراجعة والمراجعة والمراجعة والمراجعة والمراجعة والمناسبة	_BASEPLATE	VOLTAGE
211		☐ THREAD		,	11 11	
64	COLUMN	☐ FLANGE _	21/2"	TUBE	Z SHAI	T .
-	000	BOWL	SWELE	NUMBER		CONE
	OP	ASSEMBLY _	SINGLE	OF STAGES		■ BASKET STRAINER
			MOTO	R		
60 HP	. 3 PH.	ase 60	HERTZ 46	O VOLTS	900 RPM	4411 FRAME
AURO		I MD1	M viis			
	DRA 🔼	WPI .		010RS		MOTOR NOT MOUNTED AT FACTORY ON
OTHE	HS _	TEFC	MANIE	FACTURER		VERTICAL UNITS.
	L_	EXPLOSION PRO	OOF	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
			GEAR DR	IVE		
N.H.	MFR.		SIZE		RATIO	ROTATION
FURNISHED B	Υ:	AURORA	□отн	ER\$		**************************************
		C E	ECIAL REOU	IREMENTS		
-	2000 - 70					
PUMP:	KONTE BU	Wh LINES	GHAVKA	ILEU GKE	EBSE LINE	TO LOWER
BEARIN			EPLATE 6			
PERFOR	MANCE	TEST 7	WO(2) (0A)	5 317011	STIC COM	7/26
ELECTRICAL:						
•			processor na Pro Garley processor a (1) (4750, processor de maio y 10) de la companyo del companyo del companyo de la companyo	rike a denga sikipita ari dagang adi anjarahari 1 kilipada Ingala paganda Griffith Mahagalanda		
CERTIFIED	SECTION: /	1/60 BAGE	: 308-9	CURVE NUMBER	35PP.	120092
PRINT:	•	-				
				RACTERISTIC, BU	T GUARANTEE CO	VERS ONLY GPM AND
	HEAD INDICAT		TO 9/1/35			
			ESSED FOR MANUF			
			ARE CENTIFIED CO CE AT AURORA PU			LL
4			CE AT AUTORA PU	WIT, CITT OF INDO	JOINT, UMLIF,	
THIS ORDER	R CAN BE BELL	ASED FOR MAI	NUFACTURING A	AS SHOWN □	AUTHORITY:	
			responses in the second section is a second section of the second section of the second section of the second	Marie Marie Marie de Carlo de	OFFICE:	
RELEASE FO	OR MANUFACT	URING PER AT	TACHED CHANG	E ORDER:	DATE:	

20P SERIES 1160 ____

PROPELLER

SECTION 1160 PAGE 507 DATED DECEMBER 1981. SUPERSEDES PAGE 507 DATED NOVEMBER 1972







P. O. BOX 1300 . CITY OF INDUSTRY, CA . 01749

NUMBER OF STAGES REQUIRED FOR APPLICATION. STANDARD CURVE ILLUSTRATES SINGLE STAGE PERFORMANCE ONLY



PROPELLER PUMP DIMENSIONS 20P THRU 42P

DATED FEBRUARY 1985
SUPERSEDES PAGE 309
DATED FEBRUARY 1974

- 1 FLANGES, WHEN FURNISHED, WILL BE DRILLED TO 150 LB. ASA STANDARDS, FLAT FACE, HOLES STRADDLE Q THICKNESS AS SHOWN IN CHART, UNLESS OTHERWISE SPECIFIED.
- 2 INCREASE "D" BY 2" FOR FLOOR OPENING CLEARANCE WHEN USING STRAINER.
- 3 MINIMUM SUBMERGENCE TO AVOID EXCESSIVE VORTEX FORMATION WHEN PUMPING CONTINUOUSLY. SUBMERGENCE MAY BE REDUCED FOR INTERMITTENT OPERATION. NPSH REQUIREMENTS, AS SHOWN ON PUMP PERFORMANCE CURVE, MUST ALSO BE SATISFIED.
- 4 INCREASE 50% IF STRAINER IS USED.
- (5) DIMENSION "E" SHOWN IS FOR GIVEN SIZE TOP BOWL FLANGE. WHEN INTERMEDIATE LENGTH OF COLUMN PIPE IS FURNISHED, FLANGE O.D. IS SAME AS CORRESPONDING BOWL SIZE. EXAMPLE 10P BOWL WITH 12" INTERMEDIATE COLUMN, FLANGE DIAMETER IS 16" O.D. CHECK FLOOR OPENING FOR LARGEST DIAMETER FLANGE CLEARANCE.


DISCHARGE FLANGE DATA						
SIZE	0,5,	B.C.	NO, AND SIZE DOLTS	FLANGE THICKNESS		
20	27-1/2	25	> 20-1-1/8	7/8 1-1/8		
24 30	32 38-3/4	311-1/2	28-1-1/4	1-1/8		
36 42	40	42-3/4	32-1-1/2 36-1-1/2	1-1/8		
48	59-1/2	56 62-3/4	44-1-1/2	1-3/8		

MODE	L NO.	OF ABOVE BASE	К	L	M	N	1) & Q	s O	Т	х	Y ①		
AURORA PUMP	VERTI- LINE	MIN.	STD.									STRAINER- LENGTH	
	20P20	4()	()	-14	2:()	1	110	-50		12	17	20]
	20P24	64	20	21	18	1-1/4	38	50		12	17	-00-	-
	24P34	64	()	++	-1++	1-1/4	1111	-62	-	11	21	21	
	24P30	64	30	23	20	1-1/4	44	62		14	21	21	1
	24P36	73	48	25	24	1-1/4	50	62	808	14	21	21	1
	30P30	64	0	23	20	1-1/4	44	76		18	26	26	1
	30P36	73	30	25	24	1-1/4	50	76		18	26	26	1
	30P42	81	48	27	30	1-1/4	54	76	PA	18	26	26	1
,	36P36	73	0	25	24	1-1/4	50	92		22	31	30	1
	36P42	81	30	27	30	1-1/4	54	92	SEE	22	31	30	1
	36P48	90	48	30	36	1-1/2	64	92	1	22	31	30	4
	42P42	81	0	27	30	1-1/4	54	106	1	25	36		1
	42P48	90	30	30	30	1-1/2	04	106	-1	25	36		4
	42P54	00	48	32	42	1-1/2	74	106		25	36	35	j





GENERAL ENGINEERING CONTRACTOR STATE LICENSE NO. 283812 3940 WILCOX ROAD - STOCKTON, CALIFORNIA 95205 - (209) 931-2154


> PUMP BAFFLE PLATE Ryde-Sinte Control of Plate















PACO LIFT® TYPE QDN—FOR HAZARDOUS LOCATIONS

PACO PUMPS

SUBMERSIBLE NON-CLOG PUMP SYSTEMS

Meets OSHA and EPA requirements for sewage and well Class 1, Group D. Division 1 service.

Capacities to 2200 GPM, heads to 150 feet, 4- & 6-inch discharge sizes.



Job: RYDE AVE. P.S.
ADD'N., STOCKTON
Engineer:
Contractor: WAYNE FREGIE
OPERATING DATA
Pump Symbol:
Service: SUMP PUMP
Paco Model No. 58-61215
Pump Size 6"
Duty: <u>/200</u> GPM <u>8</u> TDH
Motor: <u>5 hp 870</u> rph
3 Phase 60 Herry
460 Volt EXPL- PRFEnciosur
· Management of the Control of the C

Construction


Specifications


Motor Housing	Cast Iron	Base Plate	Steei	
Volute Casing	Cast Iron	Discharge Elbow	Cast Iron	
Impeller	Cast Iron	Discharge Guide Bracket	Nonsparking Bronze	
Shaft	Stainless Steel	Rail Guices	Nonsparking Bronze	
Impeller Screw & Washer	Stainless Steel	Lift & Support Cables	Stainless Steel	
Mechanical Seais	Carbon/Ceramic Faces S/S Spring & Fittings	O-Ring Seal	Neoprene	

PACO, a Merck and Co., Inc., Subsidiary PO Box 12924 • 845 92nd Avenue Oakland, California 94604

D5c.1N

PUMP DIMENSIONS





REF: ID-19228-1

ALL DIMENSIONS IN INCHES

- Galvanized pipe to be supplied by customer
- • 495 Vortex has rectangular base plate, all other QD base plates are "L" shaped.

Pump								DIM	ENSIC	NS						
Model No.	Α	В	С	D	E	F	G	Н	J	U	>	w	Υ	z	мс	Κ
470	4	9	7-1/2	3/4	14-1/2	8	3-7/8	2-1/4	31-1/2	3/4	2-9/16	5-5/16	1/2	29-3/4	6	2
480	4	9	7-1/2	3/4	14-1/2	B	4-1/4	2-1/4	31.3/4	1/4	3-3/4	6-1/2	1/2	33-5/16	7	2
495	4	9	7-1/2	3/4	14-1/2	U U	3-1/2	2.1/4	31-3/4	1/4	3-3/4	6-1/2	1/2	33-5/16	7	2
495 Vortex	4	9	18**	3/4	18-1/4	11-3/4	5	2-3/4	43	3/4	1/16	3	3/4	41-3/16	0	2-1/2
412	4	9	7	3/4	17	10-1/2	4-1/4	5	40-3/4	1/4	3-7/16	6-1/2	3	40-7/16	9	2-1/2
415	4	9	7	3/4	17	10-1/2	3.5/8	5	41.5/8	1/4	4-11/16	7-3/4	3	40-7/16	10-1/4	2-1/2
612	6	11	8	7/8	20	12	5	4-1/2	43-3/8	1/4	4-7/16	7-1/2	2-1/2	44-3/8	9-1/2	2-1/2

	٥٧	ERALL CL	EARANCE	DIMENSI	ONS						DIME	NSI	ONS				
Pump		LENGTH		WIE	OTH					M	OTOR	FRA	ME SIZ	Ε			
Model	Motor	Motor	Tilted	C:1	Disabase		140 TY			180 T	Y		210 T	Y		250 T	Y
	Vertical	@Motor &	@Nozzle &	Simplex	Duplex	X	МТ	MR	Х	MT	MR	Х	MT	MR	Х	MT	MR
470	22-3/4		21	15-1/4	31-3/4	35	9-1/4	4	36	8-1/2	4-7/8	42	7	5-3/4	_	_	_
480	26-3/8	z	24-5/8	16-1/2	34-1/2	35	12-1/2	4	36	11-3/4	4-7/8	42	10-1/2	5-3/4	-	-	_
495	26-3/8	<u>₹</u>	24-5/8	17-3/8	35-3/8	_		_	35	11-1/4	4-7/8	42	9-3/4	5-3/4	_	_	
495 Vortex	35	snu	33-1/4	19-1/4	39-3/8				41	16-3/4	4-7/8	47	18-1/2	5-3/4	53	17-3/4	6-3/8
412	33-1/2	M T	31-3/4	23-3/8	46-3/8	-		-	-	_	-	43	15-1/4	5-3/4	50	14	6-3/8
415	33-1/2		31-3/4	25-5/8	49-5/8	_			_	_		_			51	14-1/4	6-3/8
612	35-1/2		33-3/4	26-1/8	-			—	-			47	20-3/4	5-3/4	53	19-3/4	6-3/8

NOTE:

Check clearance dimensions to insure that pump

- 1) Clears discharge piping while in tilted position
- 2) Clears door opening while in vertical position

NOTE:


In the interest of product improvement, dimensions are subject to change without notice.



8/80 Supersedes 4/80

Paco Pumps, a division of Bultimore Aircoil Co., Inc. PO Box 12924, 845 92nd Avenue Oakland, California 94604

Paco Pumps of Canada a division of Baltimore Aircoil InterAmerican Corp. 35 Sinclair Ave., Georgetown, Ontario, Canada




10" 8312 1770 RPM 1 STAGE

10"
COLUMN
10"
CAST IRON
ELBOW
1"
LINESHAFT
1-1/2"
ENCLOSING
TUBE

DATA	VALUE	
PUMP SHAFT DIAMETER	1.1875 l	N
MAXIMUM SPHERE SIZE	1.5 IN	
Kt (THRUST FACTOR)	20 LBS./	FT.
Ka (TOTAL ROTOR WEIGHT)	17 LBS	3.
Ks (SETTING CONSTANT)	2.8 LBS./	FT.
WK ²	1.1 LBS	FT. ²
BOWL ASSEMBLY WEIGHT	265 LB	S.
EYE AREA: PROPELLER NO. B-1430-F	41.0 SQ. IN.	4 VANE
PROPELLER NO. B-1431-T	41.0 SQ. IN.	3 VANE
PROPELLER NO. B-1432-T	41.0 SQ. IN.	3 VANE
PROPELLER NO. B-1433-T	41.0 SQ. IN.	3 VANE
PROPELLER NO.		
PROPELLER NO.		
THOI ELECTION TO CONTINUE ENT	ON FURNISHING	THE PUMI

HYDRAULIC PERFORMANCE IS CONTINGENT ON FURNISHING THE PUMP WITH SPECIFIED AMOUNT OF CLEAR, FRESH, NON-AERATED WATER NOT TO EXCEED 85° F.

PUMP PERFORMANCE SHOWN IS BOWL ASSEMBLY WITH 10 FEET OF COLUMN INCLUDING A STANDARD ABOVE GROUND DISCHARGE ELBOW. ADDITIONAL COLUMN LOSSES SHOULD BE ADDED WHEN SETTINGS ARE DEEPER THAN 10 FEET AND/OR FOR OTHER DISCHARGE ARRANGEMENTS.



*This value is the minimum submergence required to prevent vortexing only. This value may need to be increased to provide adequate NPSHA.

Appendix D, Hydrologic Analysis

The hydrographs for the 100-year storm event are derived from the Depth-Frequency relationships provided in the San Joaquin County Hydrology Manual.

The hydrological analysis was performed utilizing Hydraflow Hydrographs 2008 software by Autodesk.

Subarea Buena Vista North

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009


Hyd. No. 1

1-Buena Vista North

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 2 minDrainage area = 121.600 ac Basin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 90.30 cfs
Time to peak = 634 min
Hyd. volume = 24.376 acft
Curve number = 89.6
Hydraulic length = 3950 ft
Time of conc. (Tc) = 65.80 min
Distribution = Type I

Shape factor = 484



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Hyd. No. 10


Buena Vista N-St Vol

Hydrograph type = Reservoir Storm frequency = 100 yrs Time interval = 2 min

Inflow hyd. No. = 1 - 1-Buena Vista North
Reservoir name = PS-Buena Vista

Reservoir name = PS-Buena vista

Peak discharge = 12.00 cfs
Time to peak = 562 min
Hyd. volume = 24.376 acft
Max. Elevation = 6.11 ft
Max. Storage = 9.984 acft



Pond Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Pond No. 1 - PS-Buena Vista

Pond Data


Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 4.90 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	4.90	95,832	0.000	0.000
0.10	5.00	139,392	0.270	0.270
0.20	5.10	182,952	0.370	0.640
0.30	5.20	226,512	0.470	1.110
0.40	5.30	270,072	0.570	1.680
0.50	5.40	313,632	0.670	2.350
0.60	5.50	357,192	0.770	3.120
0.70	5.60	400,756	0.870	3.990
0.80	5.70	444,312	0.970	4.960
0.90	5.80	487,872	1.070	6.030
1.00	5.90	531,432	1.170	7.200
1.10	6.00	574,992	1.270	8.470
1.20	6.10	618,552	1.370	9.840
1.30	6.20	662,112	1.470	11.310
1.40	6.30	705,672	1.570	12.880
1.50	6.40	749,232	1.670	14.550
1.60	6.50	792,792	1.770	16.320

Culvert / Orifice Structures Weir Structures

	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			



Subarea Lake Dr.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Tuesday, Jun 9, 2009

Hyd. No. 2

2-Lake Drive

= SCS Runoff Hydrograph type Storm frequency = 100 yrsTime interval = 2 minDrainage area = 4.200 acBasin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 6.669 cfs
Time to peak = 602 min
Hyd. volume = 0.842 acft
Curve number = 90.1
Hydraulic length = 925 ft
Time of conc. (Tc) = 15.40 min
Distribution = Type I
Shape factor = 484



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

= Req. Ponding Volume, DS2

Tuesday, Jun 9, 2009

= 0.034 acft

Hyd. No. 11


Lake Dr-St Vol

Hydrograph type = Reservoir Peak discharge = 4.500 cfsStorm frequency Time to peak = 100 yrs $= 596 \, \text{min}$ Time interval = 2 minHyd. volume = 0.842 acftInflow hyd. No. Max. Elevation = 2 - 2-Lake Drive $= 4.16 \, \text{ft}$

Max. Storage

Storage Indication method used.

Reservoir name



Pond Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Pond No. 2 - Req. Ponding Volume, DS2


Pond Data

Contours - User-defined contour areas. Conic method used for volume calculation. Begining Elevation = 3.80 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	3.80	871	0.000	0.000
0.10	3.90	2,613	0.004	0.004
0.20	4.00	4,356	800.0	0.012
0.30	4.10	6,098	0.012	0.024
0.40	4.20	7,841	0.016	0.040
0.50	4.30	9,583	0.020	0.060
0.60	4.40	11,325	0.024	0.084
0.70	4.50	13,068	0.028	0.112
0.80	4.60	14,810	0.032	0.144
0.90	4.70	16,553	0.036	0.179
1.00	4.80	18,295	0.040	0.219

Culvert / Orifice Structures Weir Structures [A] [B] [C] [PrfRsr] [A] [B] [C] [D] Rise (in) = 0.000.00 0.00 0.00 Crest Len (ft) = 0.000.00 0.00 0.00 Span (in) = 0.000.00 0.00 0.00 Crest El. (ft) 0.00 0.00 0.00 = 0.00No. Barrels = 00 0 0 Weir Coeff. = 3.333.33 3.33 3.33 Invert El. (ft) = 0.000.00 0.00 0.00 Weir Type 0.00 0.00 0.00 Multi-Stage No Length (ft) = 0.00= No No No 0.00 0.00 Slope (%) = 0.00n/a N-Value = .013 .013 .013 n/a Orifice Coeff. = 0.600.60 0.60 0.60 Exfil.(in/hr) = 0.000 (by Wet area) TW Elev. (ft) Multi-Stage = n/aNo No No = 0.00



Subarea Franklin Dr.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Hyd. No. 3


3-Franklin

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 1 minDrainage area = 425.200 acBasin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 182.80 cfs
Time to peak = 689 min
Hyd. volume = 83.102 acft
Curve number = 88.8
Hydraulic length = 9300 ft
Time of conc. (Tc) = 155.00 min
Distribution = Type I

= 484

Shape factor



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Tuesday, Jun 9, 2009

Hyd. No. 12

Franklin-St Vol

Hydrograph type = Reservoir Peak discharge = 33.00 cfsStorm frequency Time to peak = 587 min = 100 yrsTime interval = 1 min Hyd. volume = 83.102 acft Inflow hyd. No. Max. Elevation = 3 - 3-Franklin = 3.09 ft

= Req. Ponding Volume, DS3 Max. Storage = 38.729 acftReservoir name



Tuesday, Jun 9, 2009

Pond No. 3 - Req. Ponding Volume, DS3

Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 1.75 ft


Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	1.75	87,120	0.000	0.000
0.10	1.85	261,360	0.400	0.400
0.20	1.95	435,600	0.800	1.200
0.30	2.05	609,840	1.200	2.400
0.40	2.15	784,080	1.600	4.000
0.50	2.25	958,320	2.000	6.000
0.60	2.35	1,132,560	2.400	8.400
0.70	2.45	1,306,800	2.800	11.200
0.80	2.55	1,481,040	3.200	14.400
0.90	2.65	1,655,280	3.600	18.000
1.00	2.75	1,829,520	4.000	22.000
1.10	2.85	2,003,760	4.400	26.400
1.20	2.95	2,178,000	4.800	31.200
1.30	3.05	2,352,240	5.200	36.400
1.40	3.15	2,526,480	5.600	42.000

Culvert / Orifice Structures

Weir Structures

	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			



Subarea Plymouth Dr.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Tuesday, Jun 9, 2009

Hyd. No. 4

4-Plymouth

= SCS Runoff Hydrograph type Storm frequency = 100 yrsTime interval = 1 minDrainage area = 90.400 acBasin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 51.86 cfs
Time to peak = 637 min
Hyd. volume = 14.952 acft
Curve number = 84.5
Hydraulic length = 4225 ft
Time of conc. (Tc) = 70.40 min
Distribution = Type I
Shape factor = 484



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

= 24.00 cfs

Hyd. No. 13


Plymouth-St Vol

Hydrograph type = Reservoir
Storm frequency = 100 yrs
Time interval = 1 min
Inflow hyd. No. = 4 - 4-Plymouth

Inflow hyd. No. = 4 - 4-Plymouth Reservoir name = Req. Ponding Volume, DS4 Time to peak = 611 min Hyd. volume = 14.952 acft Max. Elevation = 1.01 ft

Peak discharge

Max. Storage = 2.240 acft



Pond No. 4 - Req. Ponding Volume, DS4


Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 0.45 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	0.45	88,862	0.000	0.000
0.10	0.55	119,354	0.239	0.239
0.20	0.65	149,846	0.309	0.548
0.30	0.75	180,338	0.379	0.927
0.40	0.85	210,830	0.449	1.376
0.50	0.95	241,322	0.519	1.895
0.60	1.05	271,814	0.589	2.484
0.70	1.15	302,306	0.659	3.143
0.80	1.25	332,798	0.729	3.872
0.90	1.35	363,290	0.799	4.671
1.00	1.45	393,782	0.869	5.540

Culvert / Orifice Structures Weir Structures [A] [B] [C] [PrfRsr] [A] [B] [C] [D] Rise (in) = 0.000.00 0.00 0.00 Crest Len (ft) = 0.000.00 0.00 0.00 Span (in) = 0.000.00 0.00 0.00 Crest El. (ft) 0.00 0.00 0.00 = 0.00No. Barrels = 00 0 0 Weir Coeff. 3.33 3.33 = 3.333.33 Invert El. (ft) = 0.000.00 0.00 0.00 Weir Type 0.00 0.00 0.00 Multi-Stage No Length (ft) = 0.00= No No No 0.00 Slope (%) = 0.000.00 n/a N-Value .013 = .013.013 n/a Orifice Coeff. = 0.600.60 0.60 0.60 Exfil.(in/hr) = 0.000 (by Wet area) TW Elev. (ft) Multi-Stage = n/aNo No = 0.00



Subarea Gardena St.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Tuesday, Jun 9, 2009

Hyd. No. 5

5-Gardena

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 2 minDrainage area = 54.600 acBasin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 41.55 cfs
Time to peak = 624 min
Hyd. volume = 9.664 acft
Curve number = 86.2
Hydraulic length = 3000 ft
Time of conc. (Tc) = 50.00 min
Distribution = Type I
Shape factor = 484




Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Hyd. No. 14

Gardena-St Vol

Hydrograph type = Reservoir Peak discharge = 10.00 cfsStorm frequency Time to peak = 592 min = 100 yrsTime interval $= 2 \min$ Hyd. volume = 9.664 acftInflow hyd. No. Max. Elevation = 5 - 5-Gardena = 0.93 ft= Req. Ponding Volume, DS5 Max. Storage = 2.315 acftReservoir name



Pond No. 5 - Req. Ponding Volume, DS5


Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 0.20 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	0.20	26,136	0.000	0.000
0.10	0.30	56,628	0.095	0.095
0.20	0.40	87,120	0.165	0.260
0.30	0.50	117,612	0.235	0.495
0.40	0.60	148,104	0.305	0.800
0.50	0.70	178,596	0.375	1.175
0.60	0.80	209,088	0.445	1.620
0.70	0.90	239,580	0.515	2.135
0.80	1.00	270,072	0.585	2.720
0.90	1.10	300,564	0.655	3.375
1.00	1.20	331,056	0.725	4.100

Culvert / Orifice Structures Weir Structures [A] [B] [C] [PrfRsr] [A] [B] [C] [D] Rise (in) = 0.000.00 0.00 0.00 Crest Len (ft) = 0.000.00 0.00 0.00 Span (in) = 0.000.00 0.00 0.00 Crest El. (ft) 0.00 0.00 0.00 = 0.00No. Barrels = 00 0 0 Weir Coeff. = 3.333.33 3.33 3.33 Invert El. (ft) = 0.000.00 0.00 0.00 Weir Type 0.00 0.00 0.00 Multi-Stage No Length (ft) = 0.00= No No No 0.00 Slope (%) = 0.000.00 n/a N-Value .013 = .013.013 n/a Orifice Coeff. = 0.600.60 0.60 0.60 Exfil.(in/hr) = 0.000 (by Wet area) TW Elev. (ft) Multi-Stage = n/aNo No = 0.00



Subarea Moreing St.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Tuesday, Jun 9, 2009

Hyd. No. 6

6-Moreing

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 1 minDrainage area = 35.900 acBasin Slope = 0.1 % Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 25.05 cfs
Time to peak = 626 min
Hyd. volume = 6.083 acft
Curve number = 85.2
Hydraulic length = 3200 ft
Time of conc. (Tc) = 53.30 min
Distribution = Type I
Shape factor = 484




Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Hyd. No. 15

Moreing-St Vol

Hydrograph type = Reservoir Peak discharge = 9.000 cfsStorm frequency Time to peak = 601 min = 100 yrsTime interval = 1 min Hyd. volume = 6.083 acft Max. Elevation Inflow hyd. No. = 6 - 6-Moreing = 0.68 ft= Req. Ponding Volume, DS6 Max. Storage Reservoir name = 1.081 acft



Pond Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Tuesday, Jun 9, 2009

Pond No. 6 - Req. Ponding Volume, DS6


Pond Data

Contours - User-defined contour areas. Conic method used for volume calculation. Begining Elevation = 0.01 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	0.01	26,136	0.000	0.000
0.10	0.11	39,204	0.074	0.074
0.20	0.21	52,272	0.105	0.179
0.30	0.31	65,340	0.135	0.314
0.40	0.41	78,408	0.165	0.479
0.50	0.51	91,476	0.195	0.673
0.60	0.61	104,544	0.225	0.898
0.70	0.71	117,612	0.255	1.153
0.80	0.81	130,680	0.285	1.438
0.90	0.91	143,748	0.315	1.753
1.00	1.01	156,816	0.345	2.098

Culvert / Ori	fice Structu	Weir Structures							
	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			



Subarea Yosemite Lake

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010


Hyd. No. 7

7-Yosemite Lake

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 5 minDrainage area = 1935.900 ac Basin Slope = 0.1 %Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 722.21 cfs
Time to peak = 755 min
Hyd. volume = 457.237 acft
Curve number = 94

Hydraulic length = 15800 ft
Time of conc. (Tc) = 263.00 min
Distribution = Type I
Shape factor = 484



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010

= 250.00 cfs

= 457.237 acft

 $= 645 \, \text{min}$

Hyd. No. 16

Yosemite Lake-St Vol

Hydrograph type = Reservoir
Storm frequency = 100 yrs
Time interval = 5 min

Inflow hyd. No. = 7 - 7-Yosemite Lake


Reservoir name = Req. Ponding Volume, DS7

Max. Elevation = 7.62 ft Max. Storage = 158.732 acft

Peak discharge

Time to peak

Hyd. volume



Pond No. 7 - Req. Ponding Volume, DS7

Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 6.75 ft


Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	6.75	827,640	0.000	0.000
0.10	6.85	8,293,824	10.470	10.470
0.20	6.95	8,311,248	19.060	29.530
0.30	7.05	8,328,672	19.100	48.630
0.40	7.15	8,346,096	19.140	67.770
0.50	7.25	8,363,520	19.180	86.950
0.60	7.35	8,380,944	19.220	106.170
0.70	7.45	8,398,368	19.260	125.430
0.80	7.55	8,415,792	19.300	144.730
0.90	7.65	8,433,216	19.340	164.070
1.00	7.75	8,450,640	19.380	183.450

Culvert / Orifice Structures

Weir Structures

	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	/ Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			



Subarea Buena Vista South

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010


Hyd. No. 8

8-Buena Vista S

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 5 minDrainage area = 477.470 acBasin Slope = 0.1 %Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 306.90 cfs
Time to peak = 660 min
Hyd. volume = 116.286 acft
Curve number = 95
Hydraulic length = 7000 ft

Time of conc. (Tc) = 116.70 min
Distribution = Type I
Shape factor = 484



Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052


Monday, Apr 26, 2010

Hyd. No. 17

Buena Vista S-St Vol

Hydrograph type= ReservoirPeak discharge= 69.29 cfsStorm frequency= 100 yrsTime to peak= 855 minTime interval= 5 minHyd. volume= 116.286 acftInflow byd. No.= 8 - 8 - 8 - Buena Vista SMax. Flevation= 5 62 ft

Inflow hyd. No. = 8 - 8-Buena Vista S Max. Elevation = 5.62 ft
Reservoir name = Req. Ponding Volume, DS8 Max. Storage = 42.786 acft



Pond No. 8 - Req. Ponding Volume, DS8

Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 4.75 ft


Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	4.75	2,134,440	0.000	0.000
0.10	4.85	2,137,925	4.904	4.904
0.20	4.95	2,141,409	4.912	9.816
0.30	5.05	2,144,894	4.920	14.736
0.40	5.15	2,148,379	4.928	19.664
0.50	5.25	2,151,864	4.936	24.600
0.60	5.35	2,155,348	4.944	29.544
0.70	5.45	2,158,833	4.952	34.496
0.80	5.55	2,162,318	4.960	39.456
0.90	5.65	2,165,803	4.968	44.424
1.00	5.75	2,169,288	4.976	49.400

Culvert / Orifice Structures

Weir Structures

	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	/ Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			



Subarea Ryde St.

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010


Hyd. No. 9

9-Ryde

Hydrograph type = SCS Runoff Storm frequency = 100 yrsTime interval = 5 minDrainage area = 167.100 acBasin Slope = 0.1 %Tc method = USER Total precip. = 3.51 inStorm duration = 24 hrs

Peak discharge = 132.63 cfs
Time to peak = 640 min
Hyd. volume = 41.576 acft

Curve number = 95
Hydraulic length = 4600 ft
Time of conc. (Tc) = 76.70 min
Distribution = Type I
Shape factor = 484




Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2008 by Autodesk, Inc. v6.052

Monday, Apr 26, 2010

Hyd. No. 18

Ryde-St Vol

Hydrograph type = Reservoir Peak discharge = 37.42 cfsStorm frequency Time to peak = 100 yrs $= 740 \, \text{min}$ Time interval = 5 minHyd. volume = 39.973 acft Inflow hyd. No. = 9 - 9 - RydeMax. Elevation = 2.56 ftReservoir name = Req. Ponding Volume, DS9 Max. Storage = 13.198 acft



Pond No. 9 - Req. Ponding Volume, DS9

Pond Data

Contours - User-defined contour areas. Average end area method used for volume calculation. Begining Elevation = 1.75 ft

Stage / Storage Table

Stage (ft)	Elevation (ft)	Contour area (sqft)	Incr. Storage (acft)	Total storage (acft)
0.00	1.75	696,960	0.000	0.000
0.10	1.85	700,009	1.604	1.604
0.20	1.95	703,058	1.610	3.214
0.30	2.05	706,107	1.618	4.831
0.40	2.15	709,156	1.624	6.456
0.50	2.25	712,206	1.632	8.087
0.60	2.35	715,255	1.639	9.726
0.70	2.45	718,304	1.646	11.372
0.80	2.55	721,353	1.653	13.024
0.90	2.65	724,402	1.659	14.683
1.00	2.75	727,452	1.667	16.350
1.10	2.85	730,501	1.674	18.024
1.20	2.95	733,550	1.681	19.704
1.30	3.05	736,599	1.688	21.392
1.40	3.15	739,648	1.694	23.086

Culvert / Orifice Structures

Weir Structures

	[A]	[B]	[C]	[PrfRsr]		[A]	[B]	[C]	[D]
Rise (in)	= 0.00	0.00	0.00	0.00	Crest Len (ft)	= 0.00	0.00	0.00	0.00
Span (in)	= 0.00	0.00	0.00	0.00	Crest El. (ft)	= 0.00	0.00	0.00	0.00
No. Barrels	= 0	0	0	0	Weir Coeff.	= 3.33	3.33	3.33	3.33
Invert El. (ft)	= 0.00	0.00	0.00	0.00	Weir Type	=			
Length (ft)	= 0.00	0.00	0.00	0.00	Multi-Stage	= No	No	No	No
Slope (%)	= 0.00	0.00	0.00	n/a					
N-Value	= .013	.013	.013	n/a					
Orifice Coeff.	= 0.60	0.60	0.60	0.60	Exfil.(in/hr)	= 0.000 (by	Wet area)		
Multi-Stage	= n/a	No	No	No	TW Elev. (ft)	= 0.00			

